

CAFE FITOUT FIRE PROTECTION KEYNOTES

EXISTING SPRINKLERS INSTALLED UNDER BASE BUILDING 'CORE & SHELL'
CAFE SCOPE TO BE REMOVED BACK TO THE BRANCH MAINS AND NEW
SPRINKLERS SHALL BE INSTALLED TO SUIT THE NEW ARCHITECTURAL




JOINT HEALTH SCIENCES CENTER - CAFE FITOUT

Prepared For: Rowan University - Rutgers Camden Board of Governors 200 Federal Street, Suite 300 Camden, NJ 08103

Contract No: 16.07011.12



One Logan Square, Suite 1510 Philadelphia, PA 19103 USA t +1 215 940 3570 f +1 215 940 3571



100 Dobbs Lane, Suite 204 Cherry Hill, NJ 08034 R.G. Vanderweil Engineers, VANDERWEIL LLP
101 Grovers Mill Road
Lawrenceville, NJ 08648

Key Plan



		— 2A172FB9CC2C4FD	
No.	Description	Date	
1	ISSUED FOR CONSTRUCTION	01/17/2020	

Drawn by: JD Project No: 16.07011.12 Reviewed by: BC

ISSUED FOR CONSTRUCTION - 01.17.20

FIRE PROTECTION -LEVEL 1 - CAFE FITOUT

CONFIRM EXACT LOCATIONS OF SPRINKLERS, PIPING, FIRE HOSE VALVES AND OTHER EQUIPMENT IN FIELD. REFER TO ARCHITECTURAL & STRUCTURAL SERIES DRAWINGS FOR STRUCTURAL FRAMING PLANS, DETAILED REFLECTED CEILING PLANS, ELEVATIONS, AND SECTIONS.

1. REFER TO DRAWING F001 FOR SYMBOLS AND GENERAL PROJECT REQUIREMENTS.

4. INSTALL SPRINKLERS IN CENTER OF SUSPENDED CEILING TILE, ALONG CENTER-LINE OF CEILING FEATURES AND IN-LINE WITH ADJACENT CEILING FIXTURES. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR SPRINKLER LOCATIONS IN FINISHED CEILINGS.

MAINTAIN SPRINKLER CLEARANCE FROM STRUCTURAL MEMBERS IN ACCORDANCE WITH THE SPECIFIC REQUIREMENTS OF NFPA 13.

MAINTAIN SPRINKLER CLEARANCE FROM CEILING AND FLOOR MOUNTED OBSTRUCTIONS SIMILAR TO (BUT NOT LIMITED TO) SHELVING, ROOM DIVIDERS, LIGHT FIXTURES, EXIT SIGNS, SOFFITS AND CHANGES IN CEILING ELEVATION, IN ACCORDANCE WITH THE SPECIFIC REQUIREMENTS OF NFPA 13.