

**Bid # 20-08 Renovations and Addition to Building #7 at  
Camden County Technical Schools Gloucester Campus  
Camden County Technical Schools Board of Education  
Clarification #1  
April 16, 2021**

This Clarification dated April 16, 2021 for **Bid # 20-08 Renovations and Addition to Building #7 at Camden County Technical Schools, Gloucester Township Campus** shall be included as part of the Contract Bid Documents.

- In Addendum #1 dated April 15, 2021, there was a typographical error on the chart on page 11 of 28 (page 4 of the ACBM Inspection Report). The Estimated Quantity shown on TSI Pipe Elbow & Joints: Gray, Fibrous, Homogenous row shall be the Entire Building / 65 units.

*TABLE II – SUMMARY OF ASBESTOS-CONTAINING BUILDING MATERIALS* contains a summary of identified or assumed ACBM within the space. This table includes the material description, location, friability, NESHAP Category, estimated quantity of the material, and general material condition.

<b>TABLE II- SUMMARY OF ASBESTOS-CONTAINING BUILDING MATERIALS</b>					
<b>Material Description</b>	<b>Material Location</b>	<b>Friable</b>	<b>NESHAP Category</b>	<b>Condition</b>	<b>Estimated Quantity</b>
Floor Tile: Green, Non-Fibrous, Homogenous	Both Classrooms	No	CAT I	Fair	1350 LF
Mastic: Black, Fibrous, Homogenous	Upper roof flashing around edge parapet	No	CAT I	Good	1350 LF
Lab Tabletop: Black, Fibrous, Homogenous	Back Class/Labroom Counter Tops	No	CAT II	Good	120 SF
TSI Pipe Elbow & Joints: Gray, Fibrous, Homogenous	Overhead Water Pipe Elbow Insulation	Yes	RACM	Fair	<b>Entire Building / 65 Units</b>

*CAT I – Category I non-friable asbestos-containing material  
CAT II – Category II non-friable asbestos-containing material  
RACM – Regulated asbestos-containing material  
SF – Square Feet  
LF – Linear Feet  
CF – Cubic Feet*

- Drawing A-7 Elevations are correct. All toilet rooms are to receive full height ceramic tile as shown. Drawing A-3 Room and Finish Schedule Room No. 7-6, 7-7 and 7-8 are incorrect as to “paint”. Please follow drawing A-7 as shown.

Bid # 20-08 Renovations and Addition to Building #7 at  
Camden County Technical Schools Gloucester Campus  
Camden County Technical Schools Board of Education