

4701 New Jersey Avenue
Wildwood, NJ 08260
Phone: 609-854-3311
Fax: 609-854-4323
www.deblasioassoc.com

**DEBLASIO &
ASSOCIATES**
CONSULTING ENGINEERS AND PLANNERS

FAX

Cover Letter

TO:	All Bidders	FROM:	Marc DeBlasio, P.E., P.P., C.M.E.
FAX:		PAGES:	2
PHONE:		DATE:	July 1, 2021
RE:	Borough of Stone Harbor Beach Patrol Headquarters SH-C-020	CC:	Suzanne Stanford, Clerk (via email) Robert Smith, Administrator (via email) William McLees (via email) Jeff Moore, PE (via email)

Urgent For Review Please Comment Please Reply Please Recycle

Comments: Please find enclosed Addendum No. 3. This addendum must be returned with all bids. The failure to return the signed receipt with the contract forms will result in a non-responsive bid.

ADDENDUM NO. 3

**To All Bidders of Beach Patrol Headquarters
Borough of Stone Harbor
Cape May County, New Jersey
D&A Project #: SH-C-020**

You are hereby notified in accordance with bid documents of the above captioned project that the following has been issued to clarify the meaning of the plans and specifications and that the conditions and specifications set forth in said addenda are to be original contract documents.

QUESTIONS

- Q.** Identify scope of work for existing site lighting and back feeding them. Where are they presently fed? Are we to cut up concrete walks or is there a junction box in old building getting removed to feed?
- A.** The power and control of the existing site lighting is from the panelboard (3 circuits) and (2) timers mounted below, same within the existing building.

The existing panelboard and trough with the timers are located in the building between the garage overhead door and the main door.

The location of the existing site lighting feed is unknown. Therefore, it is not detailed as part of the design and will be means and method.

As noted on the drawings the contractor will need to intercept and extend the feeders in kind.

The contractor will need to coordinate with the demolition contractor to identify where to intercept and the method to use to reconnect.

We do not foresee the contractor doing extensive "cutting of the concrete" far from the original building location.

THIS ADDENDUM MUST BE RETURNED WITH ALL BIDS. THE FAILURE TO RETURN THIS SIGNED RECEIPT WITH THE CONTRACT FORMS WILL RESULT IN A NON-RESPONSIVE BID

I acknowledge receipt of this addendum.

Signature

Company