

4701 New Jersey Avenue
Wildwood, NJ 08260
Phone: 609-854-3311
Fax: 609-854-4323
www.deblasioassoc.com

**DEBLASIO &
ASSOCIATES**
CONSULTING ENGINEERS AND PLANNERS

FAX

Cover Letter

| | | | |
|--------|--|--------|--|
| TO: | All Bidders | FROM: | Marc DeBlasio, P.E., P.P., C.M.E. |
| FAX: | | PAGES: | 2 |
| PHONE: | | DATE: | July 1, 2021 |
| RE: | Borough of Stone Harbor Beach Patrol Headquarters SH-C-020 | CC: | Suzanne Stanford, Clerk (via email) Robert Smith, Administrator (via email) William McLees (via email) Jeff Moore, PE (via email) |

Urgent For Review Please Comment Please Reply Please Recycle

Comments: Please find enclosed Addendum No. 4. This addendum must be returned with all bids. The failure to return the signed receipt with the contract forms will result in a non-responsive bid.

ADDENDUM NO. 4

**To All Bidders of Beach Patrol Headquarters
Borough of Stone Harbor
Cape May County, New Jersey
D&A Project #: SH-C-020**

You are hereby notified in accordance with bid documents of the above captioned project that the following has been issued to clarify the meaning of the plans and specifications and that the conditions and specifications set forth in said addenda are to be original contract documents.

QUESTIONS

- Q. Regarding the underground electrical service, would directional boring be allowed under the roadway?
- A. **No, the underground electrical service shall be installed in an open trench per Electrical – Underground Service Entrance Detail SKE-08 in Addendum #1.**

THIS ADDENDUM MUST BE RETURNED WITH ALL BIDS. THE FAILURE TO RETURN THIS SIGNED RECEIPT WITH THE CONTRACT FORMS WILL RESULT IN A NON-RESPONSIVE BID

I acknowledge receipt of this addendum.

Signature

Company