



2654 E. Sherman Ave
Vineland, NJ 08361
856-982-2755

May 15, 2023

William White
Construction Official
Construction Code Office
181 E. Commerce Street
Bridgeton, NJ 08302

Subject: Big Brothers Big Sisters 60 Landis Avenue

Dear Mr. White,

I am writing in reference to the above referenced project. According to IBC 1020.2 exception 4, there is no fire rating required for the corridor walls, doors or glazing since no spaces in the building require more than one means of egress.

Please email me at rbarreiro@barchstudios.com if you have any questions.

Best regards,

Ruth Barreiro, RA

Principal

Barreiro Architecture, LLC