

Total Allowances and Fees: \$262,000.00

Bid Price exclusive of allowances and fees (In Numbers): \_\_\_\_\_

**TOTAL BID PRICE INCL. ALLOWANCES AND FEES** (In Numbers) \$ \_\_\_\_\_

(In words) \_\_\_\_\_

Amount shall be shown in both words and figures. In case of discrepancy, the amount shown in words shall govern).

**UNIT PRICES:**

1. Submit unit prices for each item listed below. For each item, include 50' of 3/4" conduit (base pricing on utilizing EMT conduit) and associated wiring (utilize 3 #12 wiring for power and lighting devices and utilize appropriate systems wiring for other devices) including all associated fittings, boxes, hardware, flexible connections, etc. As required to completely provide the item listed. Unit price shall include connecting to currently specified wiring anywhere within 50'-0" of the new device location. For fire alarm devices, please note that system programming (and related manufacturer's representative services) associated with unit price devices is included in the base bid (see fire alarm specifications information).

A. ONE (1) 20A, 120V DUPLEX RECEPTACLE

\$ \_\_\_\_\_ each

B. ONE (1) 20A, 120V QUADRUPLEX RECEPTACLE

\$ \_\_\_\_\_ each

C. ONE (1) 20A, 120V DUPLEX GFCI RECEPTACLE

\$ \_\_\_\_\_ each

D. ONE (1) 20A, 120/277V SINGLE POLE SWITCH

\$ \_\_\_\_\_ each

E. ONE (1) 20A, 120/277V OCCUPANCY SENSOR LIGHTING CONTROL SWITCH WITH INTEGRAL MANUAL OVERRIDE

\$ \_\_\_\_\_ each

F. ONE (1) 0-10 V, 30 Ma, 8-A, 120/277 V, LIGHT EMITTING DIODE (LED) DRIVER OR FLUORESCENT ELECTRONIC BALLAST COMBINATION DIMMER SWITCH AND OCCUPANCY SENSOR

\$\_\_\_\_\_ each

G. ONE (1) TELEPHONE / DATA OUTLET

\$\_\_\_\_\_ each

H. ONE (1) TYPE "A" LUMINAIRE

\$\_\_\_\_\_ each

I. ONE (1) TYPE "B" LUMINAIRE

\$\_\_\_\_\_ each

J. ONE (1) TYPE "EXIT" LUMINAIRE

\$\_\_\_\_\_ each

K. ONE (1) FIRE ALARM AUDIO / VISUAL SPEAKER STROBE

\$\_\_\_\_\_ each

L. ONE (1) FIRE ALARM VISUAL STROBE

\$\_\_\_\_\_ each

M. ONE (1) FIRE ALARM SMOKE DETECTOR

\$\_\_\_\_\_ each

N. ONE (1) FIRE ALARM HEAT DETECTOR

\$\_\_\_\_\_ each

O. ONE (1) FIRE ALARM DUCT TYPE SMOKE DETECTOR AND HVAC EQUIPMENT SHUTDOWN INTERFACE

\$\_\_\_\_\_ each

P. ONE (1) SPRINKLER SYSTEM SWITCH CONNECTION (FLOW SWITCH OR TAMPER SWITCH)

\$\_\_\_\_\_ each

BID

000150-4  
FORM

Q. ONE (1) SECURITY SYSTEM DOOR CONNECTION (INCLUDES 120V POWER CONNECTION AS WELL AS SYSTEMS WIRING CONNECTION, FROM EITHER THE FIRE ALARM OR SECURITY SYSTEM AS REQUIRED)

\$\_\_\_\_\_ each

## PART 3 EXECUTION

### 3.01 SCHEDULE OF UNIT PRICES

- A. Unit Price No. UP-1: One (1) 20A, 120V Duplex Receptacle
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- B. Unit Price No. UP-2: One (1) 20A, 120V Quadruplex Receptacle
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- C. Unit Price No. UP-3: One (1) 20A, 120V Duplex GFCI Type Receptacle
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- D. Unit Price No. UP-4: One (1) 20A, 120/277V Single Pole Switch
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- E. Unit Price No. UP-5: One (1) 20A, 120/277V Occupancy Sensor Lighting Control Switch with Integral Manual Override
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- F. Unit Price No. UP-6: One (1) 0-10V, 30Ma, 8A, 120/277 V, Light Emitting Diode (LED) Driver or Florescent Electronic Ballast Combination Dimmer Switch and Occupancy Sensor.
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- G. Unit Price No. UP-7: One (1) Telephone/Data Outlet
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- H. Unit Price No. UP-8: One (1) Type "A" Luminaire
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- I. Unit Price No. UP-9: One (1) Type "B" Luminaire
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- J. Unit Price No. UP-10: One (1) Type "Exit" Luminaire
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- K. Unit Price No. UP-11: One (1) Fire Alarm Audio/Visual Speaker Strobe
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- L. Unit Price No. UP-12: One (1) Fire Alarm Visual Strobe
  - 1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- M. Unit Price No. UP-13: One (1) Fire Alarm Smoke Detector

1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- N. Unit Price No. UP-14: One (1) Fire Alarm Heat Detector
  1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- O. Unit Price No. UP-15: One (1) Fire Alarm Duct Type Smoke Detector and HVAC Equipment Shutdown Interface
  1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- P. Unit Price No. UP-16: One (1) Sprinkler System Switch Connection (Flow Switch or Tamper Switch)
  1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- Q. Unit Price No. UP-16: One (1) Security System Door Connection (includes 120V Power Connection as well as Systems wiring connection, from either the fire alarm or security system as required)
  1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."
- R. Unit Price No. UP-17: Interior Room Signs as specified and types shown on drawings
  1. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."

**END OF SECTION 012200**