

ADDENDUM NO. 1 TO SPECIFICATIONS ISSUED FOR:

COV BID # 2026-33 POLE BARN AT BUTLER AVENUE

**PROPOSALS TO BE RECEIVED THURSDAY, AUGUST 20, 2026, 2:00 PM
PREVAILING TIME BY THE CITY OF VINELAND.**

The following items are to be excluded from the specifications as the city will provide this work:

- 1. Site Preparation**
- 2. All concrete work (except pole footings)**
- 3. Exterior wall insulation**

The following items are to be added to the specifications for work to be done by bidder:

- 1. Include pricing of roof insulation, thickness, and R ratings.**
- 2. Insulation will be installed while roof sheets are being installed.**
- 3. Insuring that roll on insulation is sandwiched between underside of roof sheets, and top of roof Purlins.**
- 4. Insulation to be thermal with vapor barrier, reinforced, white faced polyester scrim.**
- 5. Rain gutters and down spouts on front and rear elevations.**

IMPORTANT NOTICE

- Bidders must acknowledge receipt of Addendum No. 1 in the BID PACKAGE.**
- Failure to acknowledge will result in automatic rejection of the bid.**
- All recipients of the BID will receive a copy of this Addendum.**
- The date and time for receipt of Bids remains unchanged.**

Issued By:

Miguel A. Mercado, QPA
Purchasing Agent
City of Vineland

Issued Date: August 4, 2026